



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

XMT9ab-1-1-c-d-e. Digital Flow Transmitter.

XP/I/1/BCD/T6 Ta = -40°C to +60°C; IP67

a = Branding name and software type 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9.

b = Branding name and software type 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9.

c = Power 1 or 2.

d = Display 0 or 1.

e = I/O card A or B.

XMT9abJB-1-1. Junction Box.

XP/I/1/BCD/Ta = -40°C to +105°C; IP67

a = Branding name 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9.

b = Branding name 0, 1, 2, 3, 4, 5, 6, 7, 8 or 9.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D hazardous (classified) locations, indoors and outdoors (IP67).

FM Approved for:

GE Infrastructure Sensing
Billerica, Massachusetts, USA

To verify the availability of the Approved product, please refer to www.approvalguide.com



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3810	2005
ANSI/IEC 60529	2004

Original Project ID: 3047150

Approval Granted: July 18, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

J. E. Marquedant
Group Manager, Electrical

18 July 2013

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com